

TEST REPORT

Lucideon Reference: 164962 (QT39584/2/JPS)/Ref. 12

Project Title: Testing of Balustrade System TL-4010 in Accordance with BS 6180:2011

Barriers In and About Buildings

Client: OnLevel Gmbh

Groendahlscher Weg 87

46446 Emmerich

Germany

For the Attention of: Mr Frank Verhey

Author(s): Miss Lisa Cobden

Report Date: 16 March, 2017

Purchase Order No.: 71160562 FV

Work Location: Lucideon UK

Miss Joanne Booth **Consultancy Team**

pame food

Reviewer

Miss Lisa Cobden Consultancy Team Project Manager

bu Col-





CONTENTS

		Page
1	INTRODUCTION	3
2	TEST SAMPLES	3
3	TEST PROGRAMME	3
4	TEST METHOD	3
5	RESULTS	4
TA	BLES	5-6
PL	ATE	7
CH	IART	8
ΑP	PPENDIX - Figures	



1 INTRODUCTION

Lucideon were commissioned by the client, OnLevel Gmbh, to carry out load testing in accordance with BS 6180:2011 Barriers in and about buildings, to allow their balustrade system to be classified for use in accordance with BS 6180:2011 Barriers in and about buildings – Code of Practice.

The testing was carried out at OnLevel's facilities at Innovatielaan 25 8447 SN Heerenveen The Netherlands.

This report summarises the test results obtained during the test programme and does not provide interpretation of those results.

2 TEST SAMPLES

The aluminium channel tested was designated as System TL-4010. The system is shown in Figure 1.

The channel was installed by OnLevel personnel.

3 TEST PROGRAMME

A horizontal line load was carried out on the aluminium channel with the following glass types installed:

- Laminated Tempered Glass with PVB Foil 8 8 4– size (w x h):1000 mm x 1250 mm.
- Laminated Tempered Glass with PVB Foil 10 10 4 size (w x h):1000 mm x 1250 mm.
- Laminated Tempered Glass with DG41 Foil 10 10 4 size (w x h):1000 mm x 1250 mm.
- Monolithic Tempered 19 mm size (w x h): 1000 mm x 1250 mm.
- Monolithic Tempered 15 mm size (w x h): 1000 mm x 1250 mm.

4 TEST METHOD

The channel was bolted to the top of a concrete block, nominally $0.5 \text{ m} \times 0.5 \text{ m} \times 3.5 \text{ m}$ which was fixed to the floor of the test facility. The 1.0 m length of channel was bolted to the block at 200 mm centres by the client using the appropriate fixings (see Figure 1 and Figure 2).

The appropriate thickness glass panel was fitted into the channel using 'Flex Fit' fixing clips at the appropriate centres such that the plastic clip was to the outside face of the glass, (see Figures 3 and 4).

A horizontal imposed line load was applied to the glass at a height of 1297 mm above the datum level of the floor and the deflection measured at the top central point of the panel 1297 mm above the datum level of the floor. The load was applied via a hydraulic



ram and the deflection measured using a digital electronic displacement transducer, (see Plate 1).

5 RESULTS

The test was carried out in accordance with the guidance given in BS 6180 Barriers in and about buildings — Code of Practice. The standard states that the maximum allowable deflection for a free standing glass protective barrier panel is 25 mm.

Table 2 of BS 6180 Barriers in and about buildings – Code of Practice categorises parapets, barriers and balustrades for areas of use depending on the loads they have achieved under testing.

The loads achieved by the OnLevel glazing system tested under horizontal imposed line load to the maximum deflection of 25 mm are given in Table 1.

All figures quoted in Table 1 contain no safety factors and are direct loads as achieved by the system under test conditions.

Table 2 summarises the suitability of the tested systems in accordance with Table 2 of BS 6180:2011.

NOTE: The results given in this report apply only to the samples that have been tested.

END OF REPORT





Table 1 - Summary of Performance of OnLevel Balustrade System Tested under Horizontal Imposed Line Load

Base Rail	Glass	Height of Applied Load mm	Imposed Line Load at 25 mm Deflection (kN/m)	Working Line Load for System (kN/m)	Deflection at Working Line Load for System (mm)
	8/8/4	1297	0.80	0.74	22.74
Cycham	10/10/4	1297	0.75	0.74	22.56
System TL-4010	10/10/4 DG	1297	1.99	1.50	Working Line Load for System (mm) 22.74
12-4010	15 mm	1297	0.81	0.74	22.08
	19 mm	1297	1.67	1.50	21.04



Test Report: 164962/Ref. 12

Table 2 - Summary of Suitability of OnLevel Balustrade Systems in Accordance with Table 2 of BS 6180:2011

Type of Occupancy	_	Horizontal Uniformly	TL-4010 Height of Applied Load 1272 mm				
for Part of the Building	Examples of Specific Use	Distributed Line Load (kN/m)	8/8/4	10/10/4	10/10/4 DG	19 mm	15 mm
Domestic and residential	(i) all areas within or serving exclusively one single family dwelling including stairs, landings, etc. but excluding external balconies and edges of roofs	0.36	✓	~	✓	~	√
activities	(ii) other residential, i.e. houses of multiple occupancy and balconies, including Juliette balconies and edges of roofs in single family dwellings	0.74	✓	✓	✓	~	✓
Officer and	(iii) light access stairs and gangways not more than 600 mm wide	0.22	✓	✓	✓	✓	✓
Offices and work areas not included elsewhere.	(iv) light pedestrian traffic routes in industrial and storage buildings except designated escape routes	0.36	✓	✓	√	✓	✓
including storage areas	(v) areas not susceptible to overcrowding in office and institutional buildings, also industrial and storage buildings except as given above	0.74	~	~	✓	~	✓
Areas where people might congregate	(vi) areas having fixed seating within 530 mm of the barrier, balustrade or parapet	1.50	Х	Х	✓	√	Х
Areas with tables or fixed seating	(vii) restaurants and bars	1.50	X	×	✓	~	Х
Areas without	(viii) stairs, landings corridors ramps	0.74	✓	✓	✓	✓	✓
obstacles for moving people and not susceptible to overcrowding	(ix) external balconies including Juliette balconies and edges of roofs; footways and pavements within building cartilage adjacent to basement/sunken areas	0.74	✓	✓	✓	✓	√
_	(x) footways or pavements less than 3 m wide adjacent to sunken areas	1.50	Х	Х	✓	✓	Х
Areas susceptible to overcrowding	(xi) theatres, cinemas, discotheques, bars, auditoria, shopping malls, assembly areas, studios; footways or pavements greater than 3 m wide adjacent to sunken areas	3.00	x	х	Х	x	х
	(xii) grandstands and stadia	(Note 1)	-	-	_	-	-
Retail areas	(xiii) all retail areas including public areas of banks/building societies or betting shops	1.50	х	х	✓	✓	Х
Vehicular	(xiv) pedestrian areas in car parks, including stairs, landings, ramps, edges of internal floors, footways, edges of roofs	1.50 (Note 2)	Х	х	✓	√	Х
	(xv) horizontal loads imposed by vehicles	(Note 2)	-	-	-	-	-

Note 1 – See requirements of the appropriate certifying authority

Note 2 – Clause 8.1.1 of BS 6180:2011 states that "glass should not be used for vehicle protection barriers"



Test Report: 164962/Ref. 12








Plate 1 - Generic Test Arrangement






















Material: Aluminum 6063-T6

Designed by	Created	Modificated	Comment			
FV	09-Dec-16					
		Description				
ONLEVE BALUSTRADES		Profile TL-4010 L =2500mm / L=5000mm				
		Article number TL-4010	(top mount)	Size A4	Scale -	



ITEM	PCS (L=2500mm)	PCS (L=5000mm)	Description	
1	8	16	Flex-Fit 1.0KN	
2	8	16	Glass Wedge 1.0KN	
3	1 (L=2500mm)	1 (L=5000mm)	Rubber User Side	
4	1 (L=2500mm)	1 (L=5000mm)	Rubber Falling Side	

Distance Glass Carrier / Glass Wedges :



Designed by Created		Modificated	Comment			
FV 09-Dec-16						
		Description				
ONLEVE BALUSTRADES		Flex-Fits sets (quantity and distance)				
		Article number TL-4010	(top mount)	Size A4	Scale -	